



Filing Receipt

Received - 2022-01-06 10:39:37 AM
Control Number - 52667
ItemNumber - 17



Karnes Electric Cooperative, Inc.
Project No. 52667 Compliance Report

This report was prepared by Karnes Electric Cooperative, Inc. (KEC) to comply with PUCT Project No. 52667 regarding the Filing of Attestations Demonstrating Compliance with HB 4150.

| | |
|--|-----------------------------------|
| Report Date | December 23, 2021 |
| Entity | Karnes Electric Cooperative, Inc. |
| ERCOT Entity Type | Distribution Service Provider |
| Lake listed in PURA § 38.004(b) in Karnes EC Service Area | Choke Canyon Reservoir |
| County of Lake and Distribution Line | Live Oak and McMullin County |



Line and Compliance Information

| Line Identifier | Compliance with NESC 232 | Compliance Confirmation Date | Notes |
|-----------------------------|-----------------------------|---------------------------------|--|
| South Calliham Feeder 12 | Yes | September 2020 | Existing Structures/Spans were surveyed and verified to be in compliance with NESC 232. |
| North Calliham Feeder 81 | Yes | September 2020 | Existing Structures/Spans were surveyed and verified to be in compliance with NESC 232. |
| South Calliham Feeder 11 | Yes | December 2021 | Existing Structures/Spans not in compliance with NESC 232 were identified and brought into compliance with NESC 232. |
| North Calliham Feeder 82 | Yes | December 2021 | Existing Structures/Spans not in compliance with NESC 232 were identified and brought into compliance with NESC 232. |
| Tilden Sub. Feeder 11 | Yes | September 2020 | Existing Structures/Spans not in compliance with NESC 232 were identified and brought into compliance with NESC 232. |
| Tilden Sub. Feeder 12 | Yes | September 2020 | Existing Structures/Spans were surveyed and verified to be in compliance with NESC 232. |
| Tilden Sub. Feeder 15 | Yes | September 2020 | Existing Structures/Spans were surveyed and verified to be in compliance with NESC 232. |
| Tilden Sub. Feeder 17 | Yes | September 2020 | Existing Structures/Spans were surveyed and verified to be in compliance with NESC 232. |

PROJECT NO. 52667

FILING OF ATTESTATION DEMONSTRATING COMPLIANCE WITH HB 4150

AFFIDAVIT OF COOPERATIVE OFFICER FOR

KARNES ELECTRIC COOPERATIVE, INC.

FILED PURSUANT TO SECTION 6 HOUSE BILL 4150


STATE OF TEXAS §

COUNTY OF <KARNES> §

BEFORE ME, the undersigned authority, on this day personally appeared, and who, after being duly sworn, stated on his or her oath he or she is entitled to make this Affidavit, and that the statements contained below are true and correct.

I, Bradley E. Bierstedt, swear or affirm that as an Electric Cooperative operating in the State of Texas and the Electric Reliability Council of Texas (ERCOT) region and control system, confirms the following:

- Karnes Electric Cooperative, Inc. (KEC) operates a distribution utility system in the State of Texas and the Electric Reliability Council of Texas (ERCOT) region and control system;
- KEC owns (8) distribution lines over Choke Canyon Reservoir, a lake listed in PURA § 38.004(b).
- The report prepared by KEC, titled **Project No. 52667 Compliance Report**, certifies that these distribution lines meet the applicable vertical clearance requirements established in Rule 232 of the NESC Standard ANSI (c)(2).



{Signature of Officer of the Cooperative}

Bradley E. Bierstedt

General Manager


Karnes Electric Cooperative, Inc.

Sworn and subscribed before me on this 5th day of January 2022



Notary Public in and for the State of Texas

Notary



(Must be notarized by a notary public in and for the State of Texas)